

Analogni Tester otpornosti izolacije

KEW 3431










- Kompaktan dizajn male težine.
- Svetlo skale i LED svetlo za omogućavanje rada u slabo osvetljenim lokacijama ili noću.
- Ugrađeni senzor osvetljenosti automatski uključuje/isključuje svetla.
- Test sonda sa daljinskim kontrolnim prekidačem je u standardnom sastavu kompleta.
- Upozorenje na napajno kolo sa treperećim LEDom i zvukom.



Otpornost izolacije			
Test napon	250V	500V	1000V
Maks. efektivna vrednost skale	200MΩ		2000MΩ
Srednja vrednost skale	5MΩ		50MΩ
Prvi efektivni merni opsezi	0.1MΩ - 100MΩ		1MΩ - 1000MΩ
Preciznost	±5% prikazane vrednosti		
Drugi efektivni merni opsezi	Merni opsezi drugačiji od iznad, 0 i ∞		
Preciznost	±10% prikazane vrednosti		
AC napon			
AC naponski opseg	AC 600V (45 - 65Hz)/DC 600V		
Preciznost	±5% prikazane vrednosti		
Primenjeni standardi	CAT III 600V		
Izvor napajanja	LR6/R6(AA)(1.5V) × 4		
Dimenzije	97(L) × 156(W) × 46(D)mm		
Težina	oko 430g		
Dodaci	7260(Test kabl set sa daljinskim kontrolnim prekidačem), 7261(Aligator štipaljka), 9173(Torba za nošenje), 8017A(Dugačka produžna pipalica), 9121(Naramenik), LR6(AA) × 4, Uputstvo za upotrebu		
Opcioni dodaci	7243(L-oblik sonda),8016(Kuka tip pipalica)		

Dodaci/Opcioni dodaci/Povezani proizvodi

 <p>MODEL 7243</p>	 <p>MODEL 7260</p>	 <p>MODEL 7261</p>	 <p>MODEL 8016</p>
 <p>MODEL 8017A</p>	 <p>MODEL 9121</p>	 <p>MODEL 9173</p>	

Melco Buda d.o.o.

- kancelarija u Beogradu: Jurija Gagarina br.257/III sprat/12 , 11070 Novi Beograd
tel: 011/6277-410, mob: 065/311-9422

e mail: office-beograd@melcobuda.co.rs , budimir.melcobuda@gmail.com
www.melcobuda.co.rs , www.kyoritsu-instrumenti.com , www.termovizija.com , www.hioki-instrumenti.com

- kancelarija u Despotovcu: Saveza Boraca br.7, 35213 Despotovac, Srbija
tel:035/612 916, faks:035/613 319, mob. 063/8003370

e mail: office@kyoritsu-instrumenti.com , office@melcobuda.co.rs

- Germany address: Quer strasse 18 Offenbach